

**ADDENDUM NO. 02**

for

Ascension Parish School Board

Owner

for

**Districtwide Lobby Renovations  
Phase One:  
Gonzales Middle School  
SB-10731**

Project

March 21, 2019

Date

Crump Wilson Architects, LLC

Architect

Note: The attached are memoranda of changes, corrections, deletions and/or additions to the Bidding Documents, Specifications, and Drawings of the above referenced project dated January 31, 2019. Such changes, corrections, deletions and/or additions are being made prior to the bidding of the project. Where this addendum differs from the Bidding Documents, Specifications, Drawings, and previously issued addenda, this Addendum No. 02 shall govern.

**SPECIFICATIONS**

2-1 Section 23 74 20 - VRV Unit

2-1.1 At subparagraph 4.5.H.2, change “Lonworks” to “BACnet”

**DRAWINGS**

2-2 Sheet M101

2-2.1 At General Mechanical Notes, change Note No. 01 to read, “All air handling/condensing units, outside air handling unit/condensing unit, VRV air handling/condensing units on this project shall be provided with a 5 year parts and labor warranty.”.

**APPROVED EQUALS**

**NOTE:** Acceptance of a particular manufacturer does not excuse that particular manufacturer from meeting the plans and specifications. Compliance with specifications is the responsibility of the approved manufacturer.

**MECHANICAL**

<u>Product</u>	<u>Model</u>
Fans	Pennbarry Twin City
Relief/Intake Hoods	Pennbarry
Louvers	Pottorff

**END OF ADDENDUM NO. 02**