


- GENERAL NOTES:**
- ALL WORK SHALL MEET OR EXCEED ALL NEC STANDARDS.
  - SEE MAIN ELECTRICAL GENERAL NOTES FOR MORE INFORMATION.
  - COORDINATE ALL WORK WITH OTHER TRADES PRIOR TO ROUGH-IN.
  - VERIFY THE COLOR OF ALL LIGHT FIXTURES, DEVICES AND COVER PLATES WITH OWNER.
  - PROVIDE ELECTRICAL CONNECTION AND SAFETY SWITCH TO MECHANICAL/PLUMBING EQUIPMENT. VERIFY THE ELECTRICAL REQUIREMENTS WITH MANUFACTURERS NAMEPLATE AND COORDINATE ELECTRICAL LOCATION WITH EQUIPMENT SUPPLIER PRIOR TO ROUGH-IN.

- PLAN NOTES:**
- PROVIDE JUNCTION BOX WITH 120V CIRCUIT OR CONNECTION TO MAGNETIC DOOR HOLD/OPEN DEVICES. COORDINATE WITH FIRE ALARM DESIGN. SEE E3 SERIES DRAWINGS FOR MORE INFORMATION.
  - PROVIDE LITHONIA DMI (232) MOLT GEB10S LUMINAIRE AND GCI SERVICE RECEPTACLE. ALL MOUNT IN ELEVATOR SHAFT AT BOTTOM AND AT TOP PER MANUFACTURERS RECOMMENDATIONS. LUMINAIRE MUST NOT BE CONNECTED ON LOAD SIDE OF RECEPTACLE.
  - PROVIDE SIMPLE RECEPTACLE OR ELEVATOR SUMP PUMP. VERIFY ALL ELECTRICAL REQUIREMENTS AND ELECTRICAL LOCATION WITH EQUIPMENT SUPPLIER PRIOR TO ROUGH-IN.
  - EXHAUST FAN PROVIDED BY OTHERS. WIRE BY EC. CONNECT TO LIGHTING IN ROOM. PROVIDE FAN AND CONTROLS.
  - COORDINATE TELEVISION MOUNTING HEIGHT WITH ARCHITECT PRIOR TO ROUGH-IN.



**CONTRACTOR NOTE:**  
 IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO NOTIFY THE ARCHITECT, LANDLORD AND TENANT OF ANY DISCREPANCIES ENCOUNTERED ON THE PLANS OR IN EXISTING SITE CONDITIONS PRIOR TO SUBMISSION OF BID.  
 BIDDERS ARE TO VISIT THE SITE AND FAMILIARIZE THEMSELVES WITH THE EXISTING CONDITIONS AND SATISFY THEMSELVES AS TO THE NATURE AND SCOPE OF THE WORK. THE BASE BID SHALL REFLECT MODIFICATIONS TO SYSTEMS AND DEVICES AS REQUIRED BY STATE, LOCAL AND FEDERAL CODES. WHETHER INDICATED OR NOT ON CONTRACT DOCUMENTS. THE SUBMISSION OF A BID WILL BE EVIDENCE THAT SUCH AN EXAMINATION AND COMPLIANCE WITH GOVERNING CODES/REQUIREMENTS HAS BEEN MADE. LATER CLAIMS OR LABOR, EQUIPMENT, OR MATERIALS REQUIRED, OR CORRECTIONS ENCOUNTERED WHICH COULD HAVE BEEN FORESEEN HAD AN EXAMINATION AND CODE/REQUIREMENTS REVIEW BEEN MADE, WILL NOT BE ALLOWED.



**2 | POER PLAN | STORAGE BUILDING**  
**E2.1.3 | 18" x 110"**

**1 | POER PLAN | 1ST FLOOR**  
**E2.1.3 | 18" x 110"**

BIM Server: Server2012 - BIM Server (18/07/2017) Concordia Baton Rouge | Ver: 18.001 | Wednesday, September 02, 2015 | 4:04 PM