

**GENERAL NOTES:**

- A. ALL I/O SHALL MEET OR EXCEED ALL NEC STANDARDS.
- B. SEE MAIN ELECTRICAL GENERAL NOTES FOR MORE INFORMATION.
- C. COORDINATE ALL I/O WITH OTHER TRADES PRIOR TO ROUGH-IN.
- D. VERIFY THE ACT LOCATION AND MOUNTING HEIGHTS FOR ALL DEVICES AND DEVICES PRIOR TO ROUGH-IN.
- E. PROVIDE 3/4" CONDUIT IN ATTIC SPACE AT EVERY DATA DROP ROUGH-IN LOCATION.
- F. VERIFY THE COLOR OF ALL DEVICES AND COVER PLATES WITH OWNER.
- G. PROVIDE ELECTRICAL CONNECTION AND SAFETY SWITCH TO MECHANICAL/PLUMBING EQUIPMENT. VERIFY THE ACT REQUIREMENTS WITH MANUFACTURER'S NAMEPLATE AND COORDINATE WITH LOCATION WITH EQUIPMENT SUPPLIER PRIOR TO ROUGH-IN.

**PLAN NOTES:**

1. PROVIDE JUNCTION BOX WITH 120V CIRCUIT OR CONNECTION TO MAGNETIC DOOR HOLD OPEN DEVICES. COORDINATE WITH FIRE ALARM DESIGN. SEE E3 SERIES DRAWINGS FOR MORE INFORMATION.



**CONTRACTOR NOTE**  
 IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO NOTIFY THE ARCHITECT, LANDLORD AND TENANT OF ANY DISCREPANCIES ENCOUNTERED ON THE PLANS OR IN EXISTING SITE CONDITIONS PRIOR TO SUBMISSION OF BID. BIDDERS ARE TO VISIT THE SITE AND FAMILIARIZE THEMSELVES WITH THE EXISTING CONDITIONS AND SATISFY THEMSELVES AS TO THE NATURE AND SCOPE OF THE WORK. THE BASE BID SHALL REFLECT MODIFICATIONS TO SYSTEMS AND DEVICES AS REQUIRED BY STATE, LOCAL AND FEDERAL CODES. WHETHER INDICATED OR NOT ON CONTRACT DOCUMENTS, THE SUBMISSIONS OF A BID WILL BE EVIDENCE THAT SUCH AN EXAMINATION AND COMPLIANCE WITH GOVERNING CODES/REGULATIONS HAS BEEN MADE. LATER CLAIMS FOR LABOR, EQUIPMENT, OR MATERIALS REQUIRED, OR FOR OTHER COSTS ENCOUNTERED WHICH COULD HAVE BEEN FORESEEN HAD AN EXAMINATION AND CODE/REGULATIONS REVIEW BEEN MADE, WILL NOT BE ALLOWED.

**1 | PO | ER PLAN | 2ND | LOOR**  
**E2.2.4** 1/8" = 1'-0"  
 NORTH

**WATERSTONE AT BATON ROUGE  
 ASSISTED LIVING & MEMORY CARE**  
 SIEGEN LANE  
 BATON ROUGE, LA 70810

ISSUE: **PERMIT SET**

©2015 PI ARCHITECTS, INC.  
 REVISIONS:

DATE: 03/31/2016  
 PROJECT NUMBER: PES 15090  
 SHEET TITLE: PO | ER PLAN | 2ND | LOOR

SHEET: **E2.2.4**

BIM Server: Server2012 - BIM Server (18/01/14017 Concordia Baton Rouge) | Ver: 18.0011 | Wednesday, September 02, 2015 | 4:04 PM